

## Installation Instructions

ITEM: MN01

DESCRIPTION: Moulton Pendant

IP  
20



CE

RoHS



### NOTICE

1. This fitting requires 100-240V AC/50HZ power input to the driver.
2. Do not interchange any parts of this fitting.
3. A minimum distance of 50mm is required around the fitting to allow for air ventilation.
4. Allow a minimum distance between fitting and illuminated subject of 200mm.
5. Do not touch fitting when in use.
6. Do not cover with any form of heat proof material.
7. If you have any questions about the installation of this product, please contact Mondolux.

### INSTALLATION PROCESS

1. Please switch off the power.
2. Drill 2 holes in the ceiling and insert the wall plugs into them. (see Picture 1)
3. Mount the bracket on the ceiling by fixing two screws into the wall plugs. (see Picture 2)
4. Insert the power cables from the ceiling into the suspension. (see Picture 3)
5. Mount the suspension onto the bracket by pushing two screws from the side. (see Picture 4)
6. Fix the LED lamp into the lamp holder. (see Picture 5)
7. Switch on the power and the fitting should light up.
8. The installation is complete.

